

<b>Swimming Pool - Safety Checklist</b> Recommended minimum frequency Monthly during use season				
Municipality:			Inspection Date: 201__	
Name of Inspector:			Title:	
Location Surveyed:				
#	Needs Work	O K	N/A	Condition: Write line #'s & comments on back for all "Needs Work" listings
<b>Signage</b>				
1				Load rating for pool posted? (8:26 - 3.3)
2				All pool rules & restrictions are posted? i.e. no alcohol
3				Warning signs posted restriction, "prolonged breath holding"?
4				Is the UV burn index forecast posted daily?
<b>Life Guard Stand</b>				
5				One elevated lifeguard chair is required for each 3,400 ft <sup>2</sup> of pool surface
6				A complete spine board with all necessary ties?
7				A unit of lifesaving equipment provided for each 2,000 ft <sup>2</sup> of water surface area
8				A rescue tube or rescue buoy at each pool lifeguard station?
9				Suction break E-switch installed and labeled?
10				All lifeguards have a loud whistle to alert bathers?
11				Lifeguards wear hats, sunglasses and sunscreen? Shade provided?
<b>Wading pools/ spas</b>				
12				Separate filtration system and turnover rate? Rate =          gpm
13				Physical barrier separating it from other pools?
14				Suction outlet covers life span on the cover, replaced if expired?
<b>Diving boards/ sliding boards</b>				
15				Instruction signs and rules posted near the device?
16				Boards have slip-resistant tread surfaces? Slides have running water?
17				Steps & ladders lead to diving boards with handrails to water edge?
<b>Pool Depth Markings</b>				
18				Depth markings are displayed at pool edge & top surface every 25 feet?
19				Depth markings placed at Max & Min points
20				Markings must be minimum 4 inches high in a contrasting color?
<b>Written Plans to guide lifeguard actions</b>				
21				Copy of NJAC 8:26 available to Pool management?
22				A written aquatics supervision plan is available to all lifeguards?
23				A written Emergency Plan is available to all lifeguards? Posted? ○
24				Facility has a written lightning response plan?
<b>Chlorine/disinfection treatment areas</b>				
25				Identification signs posted?
26				Is there a working hardwired phone accessible to pool management for emergencies?
27				Pool makeup water protected by a backflow prevention device?
28				Automatic disinfectant leak detector & alarm installed?
29				Safety Shower /eye wash within 25 feet?
30				Is the Bonding & Grounding certificate posted as required by NJ Law S213?
31				Is pool provided with an automatic means of adding a disinfectant?
<b>Locker rooms</b>				
32				Slip resistant floors throughout? At least CoF of 1.5?
33				Electrical fixtures rated for wet areas? All receptacles GFCI protected?
34				Natural or mechanical ventilation provides minimum of 2 air changes/hour?